

**THE
UNIVERSITY
OF RHODE ISLAND**

**DIVISION OF
ADMINISTRATION
AND FINANCE**

PURCHASING DEPARTMENT

10 Tootell Road, Suite 3, Kingston, RI 02881 USA

p: 401.874.2171

f: 401.874.2306

uri.edu/purchasing

THINK BIG  WE DO™



DATE: 4/20/16

ADDENDUM #3

BID NO.: 100220

OPENING: 4/27/16 – 3:00 PM

COMMODITY: RENOVATIONS, BARLOW AND WELDIN INTERIOR

The attached represents addendum 3 to the above mentioned bid.

Please ensure that all addenda are acknowledged on the bid form when submitted.

Ryan Pincince, Assistant Purchasing Agent
Purchasing Department
The University of Rhode Island

Rev. 9-1-15

**BARLOW AND WELDIN HALLS
INTERIOR RENOVATIONS
URI – KINGSTON CAMPUS**

DOCUMENT 00900 – ADDENDA AND MODIFICATIONS

ADDENDUM NO. 3– Date: April 19, 2016

From: Tecton Architects, PC

*17 Railroad Avenue
Westerly, RI 02891
Tel. 401-5967555*

To: Prospective Bidders

Re: Bid #100220 – URI Barlow and Weldin Halls Miscellaneous Renovations, Kingston, RI.
OCP URI Project # KC.R.BRWL.2015.001

This Addendum forms part of the Contract Documents and modifies the Bidding Documents dated 1/25/2016 with amendments and additions noted below.

Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder.

This Addendum consists of 1 Page and the following documents: NONE.

CHANGES TO DRAWINGS

NONE

CHANGES TO PROJECT MANUAL (Questions received by email to URI Purchasing)

Question #1:

Drawings / Door Schedule remarks indicate hinges to be “US26D Finish”. US26D is Brushed Chrome, typically plated onto either a steel or brass base. Addendum #2, 087100, PP2.2, calls for hinges to be Stainless Steel base metal. US26D plating on stainless steel hinges is not available. Please Clarify.

ANSWER: HINGES SHALL BE STEEL WITH BRUSHED CHROME FINISH US26D.
MODIFY SPECS SECTION 087100, PAR. 2.2.B.1 ACCORDINGLY.

END OF ADDENDUM # 3